TRL Limited Technical Services Group



DYNAMIC RESTRAINT TEST REPORT

Customer: Invacare

Test Unit: Invacare Harrier Extra Heavy Duty

Test Number: 17NM02

Test Type: ISO/FDIS 7176-19:2001

Test Speed: 43.80 kph. (ΔV 47.78)

Test Date: 16/01/03

If you have any questions relating to this test please contact the Technical Services Group Manager:

Mr P Bignell direct line + 44 (0)1344 770125 fax: + 44 (0)1344 770356 email: pbignell@trl.co.uk switchboard: + 44 (0)1344 773131 fax: + 44 (0)1344 770356 website: http://www.trl.co.uk

DYNAMIC RESTRAINT TEST FACILITY

TEST REPORT

Test No: Date: 17NM02 16/01/03 Client: Run No:

Invacare TO1951

Test To be Conducted

Pulse Specification

ISO/FDIS 7176/19-1

Wheelchair

Model:

Harrier Extra Heavy Duty

Mass:

86.8 kg

Wheelchair Tiedown

Manufacturer:

Koller

Model:

Supermax 140 KFP0052/K

Angle front

45.0°

Angle back

25.0°

Occupant Restraint

Manufacturer

Koller KFP0037

Model:

Constant Force 3 Point Double

Vertical

Test Dummy

Hybrid 2

Sled Transducer

Endevco Uniaxial Type 7232

Serial number:

CV78(left) EE25(right)

Photography

Redlake 1000 F/sec + Photron HS Video

Test Data

Sled

Change in Velocity

47.78 km/h

Stopping Distance

489 mm

Peak Deceleration

21.99 g

Angle of dummy after impact

<45°

The results for this test formatted as defined in Sections 7.1 Test Report and in accordance with ISO/FDIS 7176/19-1 discussion document dated July 2001.

Section	Details		Tick [√] if correct	
5.2.1	During the test			
(a)	Excursion limits Wheelchair point P ≤ 200 mm [X	wc]	136.79	
	ATD knee ≤ 375 mm (2	(Knee]	326.31	
	ATD front of head ≤ 650	mm (421.04	
(b)	The ratio of X _{Knee} : X _{wc} ≥	1.17	2.38	
(c)	ATD rear of head ≤ 400	mm (378.94	
(d)	The batteries did not move completely outside of the wheelchair footprint or move into the wheel chair user's space?			
5.2.2	After the test		1	
(a)	The wheelchair remained in an upright position on the test platform?			
	The ATD remained in the wheelchair, with its torso at an angle of <45° from the vertical, when viewed from any direction?			
(b)	There were no visible signs of material failure on the wheelchair securing			
(c)	There were no components, fragments or accessories with a mass >100g that			
(d)	There were no fragmented or separated component, that may contact the occupant, produced with sharp edges of a radius <2mm?			
(e)	There were no visible signs of failure on primary load carrying components of the WC.			
(f)	There were no signs of failure on the locking mechanisms of seat adjusters of the WC.		N/A	
(g)	The ATD was removed from the wheelchair without the use of tools?		1	
(h)	The wheelchair was released from the tie-down system without the use of			
(i)	tools? The decrease of the mean H-point height ≤20%		1	

Analysed by:	Chr Walhen	Date:	16 January 2003	Р
--------------	------------	-------	--------------------	---

Pass/Fail PASS